

# CITY OF CORINTH GAS & WATER DEPARTMENT

CORINTH, MISSISSIPPI 38835-1870

TELEPHONE (662) 286-2263  
FAX (662) 286-1330

305 WEST WALDRON STREET  
POST OFFICE BOX 1870

## NOTICE TO GAS FITTERS WORKING INSIDE CG&W SERVICE TERRITORY

Gas Fitters doing work for customers of Corinth Gas & Water are required to pass an open book exam administered by CG&W and be Licensed & Bonded with the City of Corinth.

Gas Fitters installing piping, venting and appliances for new or existing customers are required to pull a permit with CG&W so items installed can be inspected.

The following items supersede Code and must be adhered to in order to pass an inspection:

- Piping joints **cannot** be concealed behind walls.
- Customer piping must be black pipe & copper tubing.
- Copper tubing must be joined via flared fittings.
- All piping must be pressure tested for a minimum period of 4 hrs using compressed air. The pressure test must be witnessed during the Gas Inspection.

If a Gas Fitter has questions about anything listed or Code related we urge them to please contact our office to speak with the Gas Inspector before starting a job.